



ISO/IEC 17025
ACCREDITED
TESTING
N° 023

Inspectra limited

Scope of Accreditation

Contact person	Maria D'Aguanno
Address	MRA049B Marsa Industrial Estate Marsa
Telephone	21226841
Company Reg. No.	C35757
Email	info@inspectra.eu
Website	www.inspectra.eu

ACCREDITATION INFORMATION - TESTING LABORATORY

Accreditation No.	023
Accreditation Certificate No.	023/1
Accredited according to	EN ISO/IEC 17025:2017
Accreditation Scope No.	S023/1
Date of issue of this Scope	Thursday, 12 December 2019

SCOPE OF ACCREDITATION

Issue No: S023/1

Page 1 of 3

TESTING LABORATORY

Laboratory Locations

Location Details	Activity	Location Code
Address MRA049B Marsa Industrial Estate Marsa	Head Office	A

Site activities performed away from the locations listed above

Location Details	Activity	Location Code
Location indicated by Customer	Testing of Cleanrooms	B

NAB-Malta is a signatory for the EA MLA in testing, calibration and inspection

National Accreditation Board - Malta (NAB - MALTA)
Mizzi House, 1st Floor, National Road, Blata l-Bajda HMR9010, Malta
Tel No. (+356) 23952510
Web: www.nabmalta.org.mt - Email: info@nabmalta.org.mt



ISO/IEC 17025
ACCREDITED
TESTING
N° 023

Inspectra limited

Scope of Accreditation

SCOPE OF ACCREDITATION S023/1 issued on 12/12/2019 Page 2 of 3

Material/ Product/ Matrix Tested	Type of test, parameter/ component/ characteristic measured, range of measurement, equipment	Standard Specifications/ In-House Methods /Techniques	Loc. code
----------------------------------	--	---	-----------

Controlled Environment Room

Cleanrooms and associated controlled environments	Airborne particle count test ≥ ISO 5 ≥ Class A	ISO 14644-3:2005 Annex B.1 ISO 14644-1:2009, 2015 Annex A	B
Cleanrooms and associated controlled environments	Airflow test 65.4 – 1080 m ³ /hr Air velocity 0.15 – 1.094 m/s	ISO 14644-3:2005 Annex B.4	B
Cleanrooms and associated controlled environments	Air pressure difference test From -70 - +70 Pa	ISO 14644-3:2005 Annex B.5	B
Cleanrooms and associated controlled environments	Installed filter system leakage test From 0.0001% to 100%	ISO 14644-3:2005 Annex B.6	B
Cleanrooms and associated controlled environments	Airflow direction test and visualization. 0.15 m/s to 1.094 m/s	ISO 14644-3:2005 Annex B.7	B
Cleanrooms and associated controlled environments	Temperature and relative Humidity test 15-30 degC 30 to 80% rH	ISO 14644-3:2005 Annex B.8, B.9 ISO 7726:1998	B
Cleanrooms and associated controlled environments	Recovery test Recovery time, recovery rate	ISO 14644-3:2005 Annex B.12	B
Cleanrooms and associated controlled environments	Containment leak test From 0.0001% to 100%	ISO 14644-3:2005 Annex B.13	B



ISO/IEC 17025
ACCREDITED
TESTING
N° 023

Inspectra limited

Scope of Accreditation

SCOPE OF ACCREDITATION	S023/1	issued on	12/12/2019	Page 3 of 3
Material/ Product/ Matrix Tested	Type of test, parameter/ component/ characteristic measured, range of measurement, equipment	Standard Specifications/ In-House Methods /Techniques	Loc. code	

END OF SCOPE

This scope of accreditation may be revised from time to time by NAB-MALTA. To obtain an up-to-date scope contact NAB-MALTA on +356 23952510 (info@nabmalta.org.mt).



NAB-MALTA

NAB-Malta is a signatory for the EA MLA in testing, calibration and inspection

National Accreditation Board - Malta (NAB - MALTA)
Mizzi House, 1st Floor, National Road, Blata l-Bajda HMR9010, Malta
Tel No. (+356) 23952510
Web: www.nabmalta.org.mt - Email: info@nabmalta.org.mt